

| LEGEND  |  |
|---|--|
| Fire - Red                                    |  |
| Burglary - Blue                               |  |
| Medical - Green                               |  |
| Hold Up - Dark Blue                           |  |
| Trouble/Maintenance/Supervisor/Misc. - Purple |  |
| Two Way Voice - Orange                        |  |
| Open / Close - Brown                          |  |
| A/C = Dealer                                  |  |
| P = Premise                                   |  |
| C = Contacts (RPs)                            |  |
| DISP = Dispatch                               |  |

The event code list should be used in conjunction with the alarm zones. During the data entry process each zone should be assigned an event code to achieve the proper handling procedure. The NMC operators will follow the instructions based on the event code entered for each zone. The call string is outlined next to the event description.

| FIRE     |                                       |                 |
|----------|---------------------------------------|-----------------|
| Event    | Alarm Type                            | Call String     |
| 100      | Fire Alarms - Verify 1st              | P-DISP-C-A/C    |
| 101      | Fire Alarms - Dispatch 1st            | DISP-P-C-A/C    |
| 121      | Hazmat Emergency - FD                 | P-C-DISP-A/C    |
| 501      | Fire Supervisory Trouble              | P-C-A/C         |
| 502      | Fire Valve Tamper                     | P-C-A/C         |
| 503      | OS&Y Tamper/Valve                     | P-C-A/C         |
| 505      | Fire Supervisory Trouble              | P-A/C           |
| 506      | PIV Tamper - No Restore               | P-C-A/C         |
| 508      | Fire Trouble - Dispatch 1st           | DISP-P-C-A/C    |
| 510      | Fire Trouble                          | A/C ONLY        |
| 511      | Fire Trouble - NTFY                   | P-C-A/C         |
| 517      | Fire Supervisory Trouble - No Restore | P-A/C           |
| 565      | Fire Trbl NTFY Premise - No Restore   | P-A/C           |
| MEDICAL  |                                       |                 |
| Event    | Alarm Code                            | Call String     |
| 200      | Medical Alarms                        | P-DISP-C-A/C    |
| 201      | Medical Alarms - Disp 1st             | DISP-P-C-A/C    |
| HOLD UP  |                                       |                 |
| Event    | Alarm Type                            | Call String     |
| 300      | Hold-up/Panic/Duress                  | DISP-C-A/C      |
| 301      | Hold-up/Panic/Duress - Verify         | P-DISP-C-A/C    |
| 302      | Hold-up/Panic/Duress - No RPS         | DISP-A/C        |
| 303      | Hold-up/Panic/Duress - PD Only        | DISP-C-A/C      |
| 304      | Hold-up/Panic/Duress - PD Only        | P-DISP-C-A/C    |
| 305      | Hold-up/Panic/Duress - PD Only        | DISP-P-C-A/C    |
| 360      | Hold-up/Panic/Duress                  | DISP-P-C-A/C    |
| BURGLARY |                                       |                 |
| Event    | Alarm Code                            | Call String     |
| 400      | Burglary Alarms                       | P-DISP-C-A/C    |
| 401      | Burglary Alarms - Disp 1st            | DISP-C-A/C      |
| 402      | Burglary - RPS B4 Dispatch            | P-C-DISP-A/C    |
| 403      | Burglary - RPS Only                   | P-C-A/C         |
| 404      | Burglary - 1st/2nd RP B4 Dispatch     | P-C-DISP-C-A/C  |
| 444      | Burglary - GD/No RPS                  | P-DISP-A/C      |
| 461      | Burglary - Disp Guard Only            | P-DISP-C-A/C    |
| 470      | Burglary - 1st RP/PD Only             | P-C-DISP-C-A/C  |
| 471      | Burglary - 1st RP/GD Only             | P-C-DISP-C-A/C  |
| 475      | Burglary - RPS B4 Guard Only          | P-C-DISP-A/C    |
| 481      | Burglary (ECV) - 1st RP B4 Dispatch   | P-C-DISP-C-A/C  |
| 3413     | Cancel (2Mins/2Mins)                  | LOG ONLY        |
| 3416     | Cancel PD Dispatch (2Min/4Hrs)        | LOG ONLY        |
| 36       | Close/Cancel (2Min/2Min)              | LOG ONLY        |
| 45       | Open/Cancel PD Dispatch (2Min/4Hrs)   | P-C-DISP-A/C    |
| 3415     | Open/Cancel PD Dispatch (2Min/4Hrs)   | LOG ONLY        |
| 3417     | Open/Cancel (2Min/2Min)               | LOG ONLY        |
| 35       | Open/Cancel (2Min/2Min)               | FULL SUPERVISED |
| 3497     | Open/Cancel/Verify (2Min/2Min)        | PREMISE         |
| 3498     | Open/Cancel/Verify (2Min/2Min)        | PREMISE         |

| TROUBLE/MAINTENANCE/SUPERVISORY/MISC. |   |                 |
|---------------------------------------|---|-----------------|
| Event                                 | Alarm Type                                      | Call String     |
| 5                                     | Disarm After Alarm                              | LOG ONLY        |
| 009                                   | Program Alter                                   | LOG ONLY        |
| 20                                    | Timer Test                                      | LOG ONLY        |
| 176                                   | Panel Tamper                                    | P-C-A/C         |
| 400                                   | Telco Tamper                                    | P-DISP-C-A/C    |
| 500                                   | Trouble Alarms (20Min Delay)                    | A/C ONLY        |
| 504                                   | Supervisory Trouble                             | A/C ONLY        |
| 512                                   | Sensor Tamper - NTFY                            | P-C-A/C         |
| 515                                   | Trouble Alarms - NTFY (5Min Delay)              | P-C-A/C         |
| 516                                   | Trouble NTFY Premise (5Min Delay)               | P-A/C           |
| 530                                   | Trouble - Masweb Log Only                       | LOG ONLY        |
| 540                                   | Supervisory (Masweb)                            | LOG ONLY        |
| 550                                   | Trouble (2Min Delay)                            | P-C-A/C         |
| 556                                   | Trouble/Low Batt/AC Fail (60Min Delay)          | A/C ONLY        |
| 560                                   | Trouble - Guard - No Restore                    | P-DISP-C-A/C    |
| 566                                   | Trouble NTFY - No Restore                       | P-C-A/C         |
| 600                                   | Low Battery (10Min Delay)                       | A/C ONLY        |
| 601                                   | Low Battery - NTFY (10Min Delay)                | P-C-A/C         |
| 602                                   | Low Battery - Msg At Prem                       | P-A/C           |
| 630                                   | Low Battery - Masweb Log Only                   | LOG ONLY        |
| 700                                   | A/C Loss  | A/C ONLY        |
| 701                                   | A/C Loss - NTFY                                 | P-C-A/C         |
| 707                                   | A/C Loss - NTFY 1st RP Only                     | P-C-A/C         |
| 730                                   | A/C Loss - Masweb Log Only                      | LOG ONLY        |
| 2000                                  | Restore   | LOG ONLY        |
| 3410                                  | Bypass  | LOG ONLY        |
| 3412                                  | Supervisory Trouble - No Restore                | P-C-A/C         |
| 4544                                  | Maintenance Alarms - No Restore                 | P-C-A/C         |
| 4820                                  | Timer Test Late Event                           | A/C ONLY        |
| 6215                                  | Test - Notify Premise                           | PREMISE         |
| 7151                                  | Carbon Monoxide - Gas Det No Restore            | P-C-A/C         |
| TWO WAY VOICE                         |   |                 |
| Event                                 | Alarm Type                                      | Call String     |
| 410                                   | Two Way Voice - Medical                         | P-DISP-C-A/C    |
| 411                                   | Two Way Voice - Burg                            | P-DISP-C-A/C    |
| 412                                   | Two Way Voice - Panic                           | DISP-C-A/C      |
| 414                                   | Two Way Voice - Burg 1st RP B4 Dispatch         | P-C-DISP-C-A/C  |
| 415                                   | Two Way Voice - Burg GD Only 1st RP B4 Dispatch | P-C-DISP-C-A/C  |
| 105                                   | Two Way Voice - Fire                            | P-DISP-C-A/C    |
| OPEN / CLOSE                          |   |                 |
| Event                                 | Alarm Type                                      | Call String     |
| 23                                    | Open - Log Only                                 | LOG ONLY        |
| 24                                    | Close - Log Only                                | LOG ONLY        |
| 32                                    | Open  | FULL SUPERVISED |
| 33                                    | Close   | FULL SUPERVISED |
| 35                                    | Open/Cancel (2Min/2Min)                         | FULL SUPERVISED |
| 36                                    | Close/Cancel (2Min/2Min)                        | LOG ONLY        |
| 45                                    | Open/Cancel PD Dispatch (2Min/4Hrs)             | P-C-DISP-A/C    |
| 3415                                  | Open/Cancel PD Dispatch (2Min/4Hrs)             | LOG ONLY        |
| 3417                                  | Open/Cancel (2Min/2Min)                         | LOG ONLY        |
| 3497                                  | Open/Cancel/Verify (2Min/2Min)                  | PREMISE         |
| 3498                                  | Open/Cancel/Verify (2Min/2Min)                  | PREMISE         |
| 7441                                  | Forced Arm                                      | LOG ONLY        |
| 7515                                  | Fail To Close                                   | P-C-A/C         |
| 7514                                  | Fail To Open                                    | P-C-A/C         |
| 7517                                  | Fail To Close/Open                              | LOG ONLY        |